

Test Report: (5120)052-0080 GALE PACIFIC USA, INC.

Received Date: February 21, 2020 Report Date: April 08, 2020

PASS

SUBMITTER

Gale Pacific Usa, Inc.

285 W Central Parkway Suite 1704, Altamonte Springs, Florida, 32746, United States



STYLE NUMBER

PRODUCT DESCRIPTION

COMMERCIAL NINETYFIVE 340 FR

EXECUTIVE SUMMARY

The submitted sample(s) MEET all the tested requirement(s).

REMARKS

Testing was outsourced to an approved subcontractor

TECHNICAL QUESTIONS Anna Gonzalski 716-531-2519

softlinestechnicalsupportMail@

us.bureauveritas.com

GENERAL

INFORMATION 716-505-3300

SIGNATURES Bureau Veritas

Consumer Products Services, Inc.

Jackie Graves Manager

Softlines Department

Mike Graves



VERITAS	
CLIENT CONTACT	MICHAEL TING
VENDOR NAME	
AGENT NAME	
FABRIC MILL NAME	
FACTORY NAME	GALE PACIFIC SPECIALTY TEXTILES
MODEL NUMBER	
COUNTRY OF ORIGIN	CHINA
MULTI CTRY OF ORIGIN	
PURCHASE ORDER NUMBER	TBD
FABRIC WEIGHT	A: 340 GSM
FABRIC CONSTRUCTION	
AGE RANGE	
END USE	SHADE STRUCTURES
DIVISION/DEPARTMENT	
CLIENT REFERENCE NUMBER	/
SUPPLIER REFERENCE NUMBER	/
SKU/SKN NUMBER	/
BUYER	/
COUNTRY OF DESTINATION	UNITED STATES
MULTI CTRY OF DESTINATION	
SIZE RANGE	
FPU#	/
GPU#	/
TYPE OF FINISH/DYE	
STYLE DESCRIPTION	A: A
COLOR(S) SUBMITTED	A: SKY BLUE /RIVERGUM/BROWN
SIZE(S) SUBMITTED	/
FABRIC COUNT	/
YARN SIZE	



SUBMITTED FIBER CONTENT	A: REQUEST FORM: HDPE
ACTUAL FIBER CONTENT	I .
SUGGESTED FIBER CONTENT	1
SUBMITTED CARE INSTRUCTION(S)	I
CLIENT EXPECTED CARE INSTRUCTION	I
SUGGESTED CARE INSTRUCTION(S)	1
PROTOCOL NUMBER	1
PROTOCOL STAR LEVEL	1
FAIL RETEST	A: NO
PREVIOUS REPORT NUMBER	1
RETEST SAMPLE NUMBER	1
REPORT EXPIRATION DATE	1
REVISION REASON	1



TEST RESULTS FOR COMMERCIAL NINETYFIVE 340 FR

TESTED PROPERTY	REQUIREMENTS	RESULTS	RATING	
Surface burning characteristics of building material (ASTM E84-19b)				
	If claimed, shall meet claim. If no claim, report flame spread index and smoke-developed index as data only.	Meet See test results	PASS	



Test Report: (5120)052-0080 GALE PACIFIC USA, INC.

Received Date: February 21, 2020 Report Date: April 08, 2020

ADDITIONAL TEST RESULTS FOR COMMERCIAL NINETYFIVE 340 FR

ASTM E84

Standard Test Method for Surface Burning Characteristics of Building Materials

Client Identification:	Coommercial NinetyFive 340FR
Product Category:	Textile Type Product
Specimen Weight (lbs.):	3.3
Specimen Thickness (in.):	0.034
Adhesive:	No – Laid over 2" hexagonal wire mesh screen and 1/4" rods for support.
Mounting:	Unadhered – sample not adhered to a substrate, instead it was laid over a 2" wire mesh and 1/4" rods
Length (ft.):	Three 8ft. pieces butted end to end
Additional Observations:	No unusual observations

Results:		
Flame Spread Index (Rounded to nearest multiple of 5):	5	
Smoke Developed*:	55	
Time to Ignite (minutes:seconds):	00:06	
Max Flame Spread Distance (ft.):	1.3	
Max Flame Spread Time (sec.):	83	
Class / Rating:	Class I or A rating	

Classification Criteria	Flame Spread Index	Smoke Developed
Class I or A:	0 – 25	450 or less
Class II or B:	26 – 75	450 or less
Class III or C:	76 - 200	450 or less

Overall Rating:	Pass
-----------------	------

NT = Not Tested, as noncompliance was found with a previous set.

NR = Not required to be tested.


M = Meets, NM = Not Meets

Notes: * - If raw data is less than 200 result is rounded to the nearest multiple of 5. If raw data is 200 or more result is rounded to the nearest multiple of 50.

EXHIBIT #1



ADDITIONAL TEST RESULTS FOR COMMERCIAL NINETYFIVE 340 FR



FLAME PROGRESSION VS. TIME


EXHIBIT #2



Test Report: (5120)052-0080 GALE PACIFIC USA, INC.

Received Date: February 21, 2020 Report Date: April 08, 2020

ADDITIONAL TEST RESULTS FOR COMMERCIAL NINETYFIVE 340 FR



LIGHT ABSORPTION VS. TIME

DATA SUMMARY:

TIME TO IGNITION (MINUTES:SECONDS) 00:06 MAXIMUM FLAME SPREAD DISTANCE (FEET): 1.3 MAXIMUM FLAME SPREAD TIME (SECONDS): 83

OBSERVATIONS: MINOR FLAMING DRIP AREA UNDER FLAME CURVE (FT MIN): 11.44 RAW FLAME SPREAD INDEX 9FT MIN): 5.89 AREA UNDER SMOKE CURVE (%A MIN): 45.87

RAW SMOKE DEVELOPED INDEX: 52.56

TOTAL GAS FLOW (L): 1451.3 TOTAL DAS FLOW (CUBIC FT): 51.3

MAXIMUM FLAME FRONT ACHIEVED (FT): 1.3 (@83s)

END OF REPORT